## **Ecoer AHRI Matchups & Ratings**

AHRI Ref # Status Status Outdoor Unit Cased Coils Furnace Total EER2 (2) SEER2 (1) High (47°F ) HSPF2 (3) Low (17°F ) CFM  214728308 Active Yes ERDA19H-60AA* N/A 55000 11.20 18.50 55000 9.20 44500 1700	AHRI Ref#	Model	Energy	0.44	Air Handlers or	F:::::::::::::::::::::::::::::::::::::	Cooling Performance			Heating Performance			CFM
214728308 Active Yes ERDA19H-60AA* N/A 55000 11.20 18.50 55000 9.20 44500 1700	ARKI KEI #	Status	Star	Outdoor Unit	Cased Coils	Furnace	Total	EER2 (2)	SEER2 (1)		HSPF2 <sup>(3)</sup>		CFIVI
	214728308	Active	Yes	ERDA19H-60AA*	N/A		55000	11.20	18.50	55000	9.20	44500	1700

Certified per AHRI Standard 210/240-2023 (1) Seasonal Energy Efficiency Ratio; (2) Energy Efficiency Ratio; (3) Heating Seasonal Performance Factor

**Energy Star** 

Both: Both of Residential Heat Pump and Residential Cold Climate Heat Pump Yes: Residential Cold Climate Heat Pump

