

IoT Gateway



Direct Connect provides automatic alerts when:

The refrigerant level is too high/low, or if there is a leak
The filter requires cleaning or replacement
System or component failure

Level	Heat Pump	Type	Create Time	Clear Time	Description
Minor alarm	Hang/Duo extraction hall	C2	08-10-2023 21:07:09	08-14-2023 07:36:25	DC bus under-voltage protection (CEC/CK) or CEC/CK report at the same when the power supply disconnected.
Revised	Hang/Duo extraction hall	C7	08-10-2023 21:07:09	08-14-2023 07:36:25	Compressor speed inconsistent fault (CEC/CK) or CEC/CK report at the same when the power supply disconnected.
Alarm	Dot Office unit 2 hall	H4	08-10-2023 11:41:58		Low voltage alarm
Alarm	Dot Office unit 2 hall	H4	08-10-2023 05:53:36	08-10-2023 08:16:17	Low voltage alarm
Minor alarm	Hang/Duo extraction hall	C2	08-10-2023 21:06:53	08-10-2023 07:36:53	DC bus under-voltage protection (CEC/CK) or CEC/CK report at the same when the power supply disconnected.



Direct Connect provides real-time / historical data on:

Cooling/heating capacity
System status (pressure, temperature)
System faults

Direct Connect electricity statistics:

Statistical runtime data
Energy consumption data
Store all historical electricity statistics

